

CITY OF THREE RIVERS

P.O. BOX 398
THREE RIVERS, TX 78071
(361) 786-2528
FAX (361) 786-3281

SURFACE WATER TREATMENT TECHNIQUE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

CITY OF THREE RIVERS, PWS ID TX1490002, failed to meet the minimum treatment technique requirements for the month of FEB 2021. Specifically, our water system had [using the "Violation List" below, enter the type of violation that occurred].

Violation List:

- **Low disinfectant (Total Chlorine) residual entering the distribution system for more than four consecutive hours.**

The City of Three Rivers has taken the following corrective actions to prevent a recurrence of the violations: Due to the Freeze Feb, 2021 causing our Chlorine to freeze we have since purchased and installed a proper heating source for the Chlorine storage room.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official:____Thomas Salazar____

Area code + phone number:_____361-786-2528___ Posted date /Delivered: 9-10-24
