

CERTIFICATE OF DELIVERY CODING TIER II

Community Public Water Systems

Non-Community Public Water Systems



PWS_1490002_CO ACONF_20260109_PN

Texas Commission on Environmental Quality
Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS: [TIER II]

Public Water System (PWS) name: CITY OF THREE RIVERS PWS ID: TX1490002

Type of violation: **Low disinfectant (Total Chlorine) residual entering the distribution system for more than four consecutive hours.**

Monitoring Period of violation: FEB 2021

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

[Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and]

[Continuous posting or direct delivery as required by 30 TAC §290.122 for non-community water systems; and]

Make an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (Check all below that apply):

- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- Email notification
- Post PN in conspicuous places within the service area
- Post PN in public places
- Posting the PN on the internet at www._____

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Name (print): Thomas Salazar Title: City Administrator
Area code + Phone: 361-786-2528 Date of Delivery: _____

Signature: T. Salazar Date Signed: 1-15-24

PUBLIC NOTICE

for Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

CITY OF THREE RIVERS, PWS ID TX1490002, failed to meet the minimum treatment technique requirements for the month of FEB 2021. Specifically, our water system had Low disinfectant (Total Chlorine) residual entering the distribution system for more than four consecutive hours.

Violation List:

- Low disinfectant (Total Chlorine) residual entering the distribution system for more than four consecutive hours.

The City of Three Rivers has taken the following corrective actions to prevent a recurrence of the violation. We have installed heaters and winter blankets to keep the chlorine from freezing.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact: Three Rivers Water Plant 361/786-2528.

Posted date /Delivered: 1/14/2026